


<p>Dated on the</p> <p>30th day of October, 2014</p>	 The Alberta Utilities Commission
<p>Appendix 1 to Decision 2014-301</p> <p>AltaGas Ltd. Parkland Gas-fired Power Plant Change in Operating Hours</p>	<p>Application No. 1610815 Proceeding No. 3392</p>

AltaGas Ltd. (AltaGas), pursuant to Approval No. [U2014-87](#),¹ is the operator of a power plant designated as the Parkland gas-fired power plant, in the Stavely area.

AltaGas, by Application No. 1610815 registered on September 2, 2014, applied to the Alberta Utilities Commission (AUC or the Commission) for approval to amend the operating hours of the power plant from the daytime period of 7 a.m. to 10 p.m., to 24 hours per day.

The Commission, pursuant to Section 11 of the *Hydro and Electric Energy Act*, approved the application in Decision 2014-301,² and granted an approval to AltaGas to amend the operating hours of the power plant, subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The power plant shall be located in the LSD 6, Section 11, Township 15, Range 27, west of the Fourth Meridian.
2. The power plant shall consist of five 2.055-megawatt (MW) natural gas-driven generators with a total generating capability of 10.275 MW.
3. AltaGas may operate the power plant 24 hours per day after meeting the condition that AltaGas installs acoustical blankets on the power plant generator exhaust silencer shells to meet the permissible sound levels specified in AUC Rule 012 during the nighttime period.
4. AltaGas shall obtain Commission approval prior to making any material changes to the power plant or substantially varying the design and/or specifications of the power plant from what was stated in the application or from what the Commission has approved.
5. This approval is not transferable unless approved by the Commission.

¹ Power Plant Approval No. U2014-87 Application No. 1610070, Proceeding No. 2916, March 11, 2014.

² Decision 2014-301: AltaGas Ltd. –Parkland Gas-fired Power Plant Change in Operating Hours, Application No. 1610815, Proceeding No. 3392, October 30, 2014.

Approval No. U2014-87 is rescinded.

The Commission may cancel or suspend this approval, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this approval, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

END OF DOCUMENT