

February 16, 2017

**Decision 22398-D01-2017**

ATCO Gas and Pipelines Ltd. (South)  
909 11 Avenue S.W.  
Calgary, Alberta T2R 1L8

Attention: Scott Salmon, P. Eng.  
Senior Engineer, UPR

**Pipelines in the Calgary Area**  
**Licence 5895**  
**Proceeding 22398**  
**Application 22398-A001**

**Record amendment application**

1. ATCO Gas and Pipelines Ltd. (South) (ATCO), by Application 22398-A001, registered on February 7, 2017, filed an application with the Alberta Utilities Commission under Section 12 of the *Pipeline Act* and Section 4.1 of the *Gas Utilities Act* for the following:

- length amendment of lines 176 and 177
- splitting of line 176 into lines 176, 202 and 203
- outside diameter amendment of lines 160 to 165 and lines 168 to 193 from 609.6 millimetres to 610 millimetres

2. The proposed amendment is related to facilities previously constructed and operating in accordance with approvals granted in Licence 5895.

3. ATCO stated that, at the time of construction, “heavy wall” pipe was utilized for the portion of original line 176 that crosses a wetland. Line 176 is split into lines 176, 202 and 203 to reflect the pipe specifications of the pipe that was actually installed. Additionally, the length of lines 176 and 177 is required to be amended to reflect the actual length of pipe installed. The original applications specified a pipe outside diameter of 609.6 millimetres. Upon further review, CSA Z245.1, Table B.1 specifies this pipe size as 610 millimetres. In this application, ATCO also requested that the correct outside diameter of 610 millimetres be reflected for lines 160 through 165 and lines 168 through 193.

4. ATCO provided information respecting the need, nature and extent of the pipeline record amendment. Since the record amendment does not involve a ground disturbance, there will be no environmental impact.

5. Based upon the information provided, ATCO has demonstrated that the proposal is of a minor nature, no other person will be directly affected by the proposal and no adverse environmental impact will be caused by the proposed record amendment.

6. The Commission approves the application. The amended licence is attached.

**Alberta Utilities Commission**

*(original signed by)*

Brian Shand, P. Eng.  
Director, Gas Facilities  
On behalf of the Alberta Utilities Commission