


<p>Dated on the</p> <p>11th day of March, 2014</p>	 The Alberta Utilities Commission
Appendix 1 to Decision 2014-061 AltaGas Ltd. Alter Parkland Gas Power Plant	Application No. 1610070 Proceeding ID No. 2916

AltaGas Ltd. (AltaGas), pursuant to Approval No. U2008-92¹ is the operator of a power plant designated as the Parkland Gas power plant, in the Stavely area.

AltaGas, by Application No. 1610070 registered on November 14, 2013, applied to the Alberta Utilities Commission (AUC or the Commission) for approval to alter and operate the power plant from a 7.2 megawatt (MW) power plant to a 10.275 MW power plant.

The Commission, pursuant to Section 11 of the *Hydro and Electric Energy Act*, approved the application in Decision 2014-061,² and granted an approval to AltaGas to alter and operate the power plant, subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The power plant shall be located in the LSD 6, Section 11, Township 15, Range 27, west of the Fourth Meridian.
2. The power plant shall consist of five 2.055 megawatt (MW) natural gas driven generators with a total generating capability of 10.275 MW.
3. AltaGas shall submit a progress report to the Commission in writing, once every three months, on construction progress pursuant to Section 3 of the *Hydro and Electric Energy Regulation*. The first progress report shall be filed with the Commission three months from the date of issuance of this approval.
4. AltaGas shall notify the Commission within 30 days of completing the alterations to the power plant.
5. Unless otherwise authorized by the Commission, the alteration shall be completed by December 31, 2014.

¹ Approval No. U2008-92 Application No. 1551820, April 18, 2008.

² Decision 2014-061: AltaGas Ltd. – Installation of Five 2.055 MW Generators, Application No. 1610070, Proceeding ID No. 2916, March 11, 2014.

6. AltaGas shall only operate the power plant during the daytime period of 7 a.m. to 10 p.m.
7. AltaGas shall obtain Commission approval prior to making any material changes to the power plant or substantially varying the design and/or specifications of the power plant from what was stated in the application or from what the Commission has approved.
8. This approval is not transferable unless approved by the Commission.

Approval No. U2008-92 is rescinded.

The Commission may cancel or suspend this approval, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this approval, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

END OF DOCUMENT