


<p>Dated on the</p> <p>11th day of March, 2014</p>	 The Alberta Utilities Commission
<p>Appendix 2 to Decision 2014-061</p> <p>AltaGas Ltd.  Connect Parkland Gas Power Plant to  the FortisAlberta Inc.  Distribution System</p>	<p>Application No. 1610070  Proceeding ID No. 2916</p>

AltaGas Ltd. (AltaGas), by Application No. 1610070 registered on November 14, 2013, applied to the Alberta Utilities Commission (AUC or the Commission) to alter and operate the Parkland power plant from 7.2 megawatt (MW) power plant to a 10.275 MW power plant. AltaGas informed the Commission that the connection point of the proposed power plant will remain the same as in Order No. 2008-93.<sup>1</sup>

Pursuant to Section 18 of the *Hydro and Electric Energy Act*, the Commission approved the application in Decision 2014-061,<sup>2</sup> and granted to AltaGas an order to connect the Parkland power plant to the FortisAlberta Inc. distribution system, subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. AltaGas may connect the power plant to the distribution system in LSD 6, Section 11, Township 15, Range 27, west of the Fourth Meridian, as indicated in the application.
2. The specifications of the connection shall be as set out in the application.
3. The connection shall be operated so that except under short-term emergency conditions:
  - a) The flows of real and reactive power are those for which the connection is designed and which it is intended to carry on a continuous basis.
  - b) No excessive surges of 60-hertz power or excessive exchange of power frequency harmonics shall occur between the systems connected.
4. This order is not transferable unless approved by the Commission.

Order No. U2008-93 is rescinded.

<sup>1</sup> Order No. U2008-93, Application No. 1551820, April 18, 2008.

<sup>2</sup> Decision 2014-061: AltaGas Ltd. – Installation of Five 2.055 MW Generators, Application No. 1610070, Proceeding ID No. 2916, March 11, 2014.

The Commission may cancel or suspend this order, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this order, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

END OF DOCUMENT