

DA2014-134

June 5, 2014

ATCO Gas and Pipelines Ltd. (South)
7210 – 42 Street N.W.
Edmonton, Alberta T6B 3H1

Attention: Jo-Anne Van Sickle
Senior Administrative Coordinator

Permit and Licence No. 10840
Application No. 1610636
Proceeding No. 3272

Record amendment application

ATCO Gas and Pipelines Ltd. (South) (ATCO), by Application No. 1610636 registered on June 3, 2014, filed an application with the Alberta Utilities Commission (AUC or the Commission) under Section 12 of the *Pipeline Act* and Section 4.1 of the *Gas Utilities Act* for the following in Township 47, Range 20 west of the Fourth Meridian:

- H₂S content amendment from 0.10 mol/kmol to 0.00 mol/kmol
- stress level amendment of Line 1 from 0 to 12
- pipe grade amendment of Line 1 from 241 1 to 35 1

The proposed amendment is related to facilities previously constructed and operating in accordance with approvals granted in Permit and Licence No. 10840.

ATCO stated that upon review of its records it was determined that there was an error regarding the H₂S content on the licence. The H₂S content should be reflected as 0.00 mol/kmol and not 0.10 mol/kmol. Additionally, the stress level of Line 1 should be reflected as 12 and not 0, as the maximum operating pressure is 4830 kPa. The grade of the pipe on the licence should also be reflected as 35 1 on the licence as that was the standard for this pipe when the pipeline was installed in 1976.

ATCO provided information respecting the need, nature and extent of the pipeline record amendment. Since the record amendment does not involve a ground disturbance, there will be no environmental impact.

Based upon the information provided, ATCO has demonstrated that the proposal is of a minor nature, no other person will be directly affected by the proposal and no adverse environmental impact will be caused by the proposed record amendment.

The Commission approves the application. The amended permit and licence is attached.

A handwritten signature in black ink, appearing to read "B. Shand". The signature is stylized and somewhat cursive.

Brian Shand, P. Eng.
Director, Gas Facilities
On behalf of the Alberta Utilities Commission

Attachment